

Cronovich, Theresa

From: Jones, George D (St. Louis)
Sent: Monday, April 18, 2016 9:14 PM
To: James.K.Moore@illinois.gov; Chris.Cahnovsky@Illinois.gov
Cc: kevin.dyer@shell.com; Mooshegian, Robert; Cronovich, Theresa; Hart, Rich
Subject: FW: Roxana SVE Shutdown

Jim:

AECOM, formerly URS, is sending this e-mail to you as required by Item 7 of IEPA's April 9, 2014 letter (Log No. B-43R-CA-65, 68, and 76) and Item 7 of IEPA's May 15, 2015 letter (Log No. B-43R-CA-66 and 84). Item 7 requires that the IEPA Bureau of Land, Permit Section, and the Collinsville Field Office be notified by e-mail if the full-scale SVE system is down for more than 72 continuous hours. We shut the system off on Friday April 15, at 2:27 p.m. due to an electrical issue in a control panel. An electrical contractor was on-site on April 18th to troubleshoot the issue and identified a loose wire associated with one of the process room control panels. The wire connection was adjusted and the system was restarted and brought on-line at 3:05 p.m. The system was off-line 72 hours and 38 minutes.

Thank You

George D. Jones
Project Manager
AECOM
1001 Highlands Plaza Drive West-Ste 300
St. Louis, Missouri 63110
Office Ph: 314-429-0100
Direct: 314-743-4160
Cell: 314-422-2793
Email: george.d.jones@aecom.com

This e-mail and any attachments contain AECOM confidential information that may be proprietary or privileged. If you receive this message in error or are not the intended recipient, you should not retain, distribute, disclose or use any of this information and you should destroy the e-mail and any attachments or copies.