

Pennington, Wendy

From: Jones, George D (St. Louis)
Sent: Tuesday, January 17, 2017 1:49 PM
To: Moore, James K.
Cc: kevin.dyer@shell.com; Cahnovsky, Chris; Search, Gina; Mooshegian, Robert; King, Angela; Hart, Rich; Pennington, Wendy
Subject: RE: Roxana SVE System Shutdown - Notification

Jim:

AECOM is sending this e-mail to you as required by Item 7 of IEPA's April 9, 2014 letter (Log No. B-43R-CA-65, 68, and 76) and Item 7 of IEPA's May 15, 2015 letter (Log No. B-43R-CA-66 and 84). Item 7 requires that the IEPA Bureau of Land, Permit Section, and the Collinsville Field Office be notified by e-mail if the full-scale SVE system is down for more than 72 continuous hours. We are providing advance notice of shutdown of the SVE system which will exceed 72 hours. A system shutdown alarm was received on Sunday January 15, 2017 at 2:23 a.m. The system was inspected on Monday January 16, 2017 and it was identified that drive belts associated with the system fan broke initiating the shutdown alarm. We have a subcontractor scheduled to replace and align the new belts with the driver and driven pulleys on January 18, 2017. AECOM will notify IEPA when the system is brought back on-line.

Thank You

George D. Jones
Project Manager
AECOM
1001 Highlands Plaza Drive West-Ste 300
St. Louis, Missouri 63110
Office Ph: 314-429-0100
Direct: 314-743-4160
Cell: 314-422-2793
New email: george.d.jones@urs.com